



CIRCUIT BREAKER TABLE				
MFG	BREAKER FRAME	AMP	KAIC	WIRE RANGE
SQUARE D	P-FRAME	800	35	(3) 3/0 - 500KCMIL
			65	
			100	



PART NUMBER:
UD-101196-AK0800DE065

- KAIC OF UNIT
035
065
100
- INTERLOCK
E - SKPM
K - KIRKKEY
- BREAKER MANUFACTURER
D - SQUARE D
- AMPERAGE OF UNIT
800
- VOLTAGE OF UNIT
K - 480V
- COLOR OF UNIT
A - BEIGE
B - BLACK



- NOTES:**
1. BYPASS DESIGNED TO BE SET ON EITHER SIDE OF UPS.
 2. APPROXIMATE WEIGHT: 750LBS
 3. THIS UNIT IS UL LISTED.
 4. CONSULT FACTORY FOR ADDITIONAL BYPASS OPTIONS.
 5. BREAKERS ARE 80% RATED.

MAINTENANCE BYPASS;800A;30IN

REVISIONS	DATE	DESCRIPTION
0. INITIAL RELEASE	3/12/2020	Z.ZAJAC
4. UPDATED SALES DRAWING FOR KIRK KEY OPTION	8/10/2020	J.PRY-SOCK
8. UPDATED APPROXIMATE WEIGHT	3/12/2021	J.PRY-SOCK

DIMENSIONS IN: IN [MM] (REF)	SCALE - NTS -	DRAFTER Z.ZAJAC	DATE 3/12/20	<p>MITSUBISHI ELECTRIC</p>
<small>PROPRIETARY</small> This document is the property of Mitsubishi Electric Power Products, Inc. and contains proprietary and confidential information which must not be duplicated, used or disclosed other than as expressly authorized by Mitsubishi Electric Power Products, Inc.		APPROVED N.RIEMER	DATE 3/12/20	
CORE/REFERENCE DRAWING (IF APPLICABLE)		DWG. NO. UD-101196(S)		SHEET 1 OF 1 REV. 8